

GLASSBORO PUBLIC SCHOOLS

CONSTRUCTION UPDATE

10/11/17

Status of work to be completed by location:

GLASSBORO HIGH SCHOOL

- Remove remaining components of old HVAC controls and boilers.
- Complete programming of new building management system
- Repair/resurface terrazzo floor in hallways
- HVAC/Plumbing punch list
 - Investigate hot water being sent to cold water fixtures
 - HVAC roof top units to be inspected and repaired
- Other trades punch list items

GLASSBORO INTERMEDIATE SCHOOL

- Complete programming of new building management system
- Additional Roof work identified to address leaks.
- Install remote freeze stats in high units
- Punch list items

BOWE

- Complete programming of new building management system
- Punch list items

BULLOCK

- Complete programming of new building management system
- Contractor to submit to repair HVAC units in Gym
- Punch list items

RODGERS

- Replace ceiling tiles
- Complete programming of new building management system
- Address heating/cooling issues in Small Group Instruction room and OT room.
- Install lockable disconnect switch for new boiler.

Beach Administration Building

- Complete server room HVAC upgrades
- Punch list items