

GLASSBORO PUBLIC SCHOOLS  
GLASSBORO, NEW JERSEY

TO: Mark Silverstein  
FROM: Scott Henry  
DATE: September 13, 2017  
RE: Discussion Item for September 19, 2017

Attached is a summary of repair activities at the Glassboro Intermediate School undertaken to ensure boilers are in proper working condition. Please place on the Operations Agenda for discussion at the committee level.

GLASSBORO PUBLIC SCHOOLS  
INTERMEDIATE SCHOOL BOILER UPDATE

9/19/17

The following is a summary of the repair activities at the Glassboro Intermediate School to ensure the boilers and chimney are in proper working order:

- Week of July 17, 2017 - Both Intermediate School boilers were opened by Monarch Boiler on the fire side and water side and cleaned. Gas leak found by South Jersey Gas was repaired and fan belts were replaced.
- July 27, 2017 – Inspector from FM Global inspected boilers while opened per state code.
- Week of August 7, 2017 – both boilers closed and prepped for startup.
- August 16, 2016 - Chimney relining and repair work completed by Continental Chimney and Engineering.
- Week of August 28, 2017 – start up technician from Monarch Boiler completed state required startup report for both units.
- September 9, 2017 – State Inspector, Michael Braciszewski inspected both units and issued “Satisfactory” report for both boilers. Certificates of Compliance will be mailed to district.
- Both boilers are ready to operate when outside temperature calls for heat.