

Attachment L - Results Summary Lead in Water Sample

School Name: George Beach Jr. Administration Building

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WF001	39-0609-AD001	Water Fountain in hall	47.1	Yes
S002	39-0609-AD002	Sink Mens Toilet (Room 12)	9.8	No
S003	39-0609-AD003	Sink Womens toilet (Room 10)	7.03	No
S004	39-0609-AD004	Sink in Mechanical (Room 9)	24.7	Yes
IM005	39-0609-AD005	Ice Machine in Mechanical (Room 9)	26.2	Yes
HB006	39-0609-AD006	Hose bib front exterior right of entrance	ND	No
QC BLANK	39-0609-AD007	DI Blank	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported