

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S001	39-0607-001	Sink A- 5	1.61	No
B001	39-0607-002	Bubbler A-5	ND	No
S002	39-0607-003	Sink A-4	ND	No
B002	39-0607-004	Bubbler - A-4	ND	No
S003	39-0607-005	Sink - A-3	6.74	No
B003	39-0607-006	Bubbler A-3	4.49	No
S004	39-0607-007	Sink A-2	1.70	No
B004	39-0607-008	Bubbler A-2	ND	No
S005	39-0607-009	Sink A-6	3.69	No
B005	39-0607-010	Bubbler A-6	1.46	No
S006	39-0607-011	Sink A-7	5.38	No
B006	39-0607-012	Bubbler A-7	NR	No
S007	39-0607-013	Sink A-8	1.11	No
B007	39-0607-014	Bubbler A-8	1.39	No
S008	39-0607-015	Sink A-9	ND	No
B008	39-0607-016	Bubbler A-9	ND	No
S009	39-0607-017	Sink A-10	5.22	No
B009	39-0607-018	Bubbler A-10	11.70	No
S010	39-0607-019	Sink A-11	3.23	No
B010	39-0607-020	Bubbler A-11	9.98	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S011	39-0607-021	Sink A-12	4.93	No
B011	39-0607-022	Bubbler A-12	1.56	No
S012	39-0607-023	Sink A-13	ND	No
B012	39-0607-024	Bubbler A-13	ND	No
S013	39-0607-025	Sink A-14	54.10	Yes
B013	39-0607-026	Bubbler A-14	31.70	Yes
S014	39-0607-027	Sink A-15	2.22	No
B014	39-0607-028	Bubbler A-15	ND	No
S015	39-0607-029	Sink Café Bathroom	ND	No
S016	39-0607-030	Sink A-22	1.97	No
S017	39-0607-031	Sink A-22	2.20	No
S018	39-0607-032	Sink A-21	4.19	No
S019	39-0607-033	Sink A-20	ND	No
S020	39-0607-034	Sink Girls Room across from A-14	ND	No
S021	39-0607-035	Sink Boys Room across from A-15	ND	No
S022	39-0607-036	Sink Kitchen	1.30	No
S023	39-0607-037	Sink Kitchen	1.30	No
S024	39-0607-038	Sink Kitchen	14.80	No
S025	39-0607-039	Sink Kitchen	1.29	No
S026	39-0607-040	Sink Kitchen	93.70	Yes

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S027	39-0607-041	Sink Kitchen	1.37	No
S028	39-0607-042	Sink Kitchen	2.50	No
S029	39-0607-043	Sink Kitchen	2.19	No
S030	39-0607-044	Sink Kitchen	3.50	No
S040	39-0607-045	Sink Kitchen	2.91	No
S050	39-0607-046	Faculty Sink	ND	No
S051	39-0607-047	Sink Kitchen	ND	No
S052	39-0607-048	Sink Kitchen	ND	No
IM001	39-0607-049	Ice Maker Kitchen	ND	No
SM001	39-0607-050	Kitchen Soup Maker	11.40	No
S053	39-0607-051	Sink B-44	1.44	No
B015	39-0607-052	Bubbler B-44	ND	No
S054	39-0607-053	Sink B-43	2.27	No
B016	39-0607-054	Bubber B-43	ND	No
S055	39-0607-055	Sink	ND	No
WF001	39-0607-056	WF in hall by Stage C-16 (left)	ND	No
S056	39-0607-057	Sink Custodial Office	5.92	No
S057	39-0607-058	Sink B-36	1.03	No
B018	39-0607-059	Bubbler B-36	ND	No
S058	39-0607-060	Sink B-35	1.22	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
B019	39-0607-061	Bubbler B-35	ND	No
S059	39-0607-062	Sink Girls Room	1.17	No
S060	39-0607-063	Sink Boys Room	ND	No
WF002	39-0607-064	WF in Hall by B-35 (middle)	ND	No
WF003	39-0607-065	WF in Hall by B-35 (right)	ND	No
S061	39-0607-066	Sink B-3	ND	No
S062	39-0607-067	Sink B-8	1.38	No
B020	39-0607-068	Bubbler B-8	ND	No
S063	39-0607-069	Sink in restroom across from C-15	ND	No
S064	39-0607-070	Sink in restroom next to C-11	ND	No
B021	39-0607-071	Bubbler between office and B-5	ND	No
S065	39-0607-072	Sink in Nurse Office	1.44	No
IC002	39-0607-073	Ice Maker in Nurse Office	ND	No
S066	39-0607-074	Sink C-41	65.80	Yes
B022	39-0607-075	Bubbler C-41	3.99	No
S067	39-0607-076	Sink C-40	50.20	Yes
S089	39-0607-077	Sink in Nurse restroom	ND	No
S068	39-0607-078	Sink C-39	8.97	No
B024	39-0607-079	Bubbler C-39	13.00	No
S069	39-0607-080	Sink C-38	6.75	No

Action Level (AL) ≥15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
WF010	39-0607-081	WF across from A-5 (middle)	ND	No
WF011	39-0607-082	WF across from A-5 (right)	ND	No
WF004	39-0607-083	WF across from C-37 (right)	ND	No
S071	39-0607-084	Sink C-25	4.14	No
B027	39-0607-085	Bubbler C-25	1.05	No
S072	39-0607-086	Sink in Demo	ND	No
S073	39-0607-087	Sink Boys Room	ND	No
S074	39-0607-088	Sink- across room C-36	ND	No
S075	39-0607-089	Sink Girls Room	ND	No
WF005	39-0607-090	WF across from C-37 (left)	ND	No
WF006	39-0607-091	WF across from C-37 (middle)	ND	No
S076	39-0607-092	Sink C-33	1.22	No
B028	39-0607-093	Bubbler C-33	ND	No
S077	39-0607-094	Sink D-2	ND	No
B029	39-0607-095	Bubbler D-2	ND	No
S078	39-0607-096	Sink D-5	1.31	No
B030	39-0607-097	Bubbler D-5	1.39	No
S079	39-0607-098	Sink D-7	2.09	No
B031	39-0607-099	Bubbler D-7	4.04	No
S080	39-0607-100	Sink D-9	1.94	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
B032	39-0607-101	Bubbler D-9	ND	No
S081	39-0607-102	Sinks D-11	9.80	No
B033	39-0607-103	Bubbler D-11	ND	No
S082	39-0607-104	Sink D-13	1.04	No
B034	39-0607-105	Bubbler D-13	1.50	No
S083	39-0607-106	Sink D-15	5.64	No
B035	39-0607-107	Bubbler D-15	1.54	No
S084	39-0607-108	Sink D-17	1.13	No
B036	39-0607-109	Bubbler D-17	ND	No
S085	39-0607-110	Sink D-19	5.87	No
B037	39-0607-111	Bubbler D-19	4.12	No
S086	39-0607-112	Sink D-21	1.05	No
B038	39-0607-113	Bubbler D-21	ND	No
S087	39-0607-114	Sink D-23	3.01	No
B039	39-0607-115	Bubbler D-23	ND	No
S088	39-0607-116	Sink D-25	1.04	No
B040	39-0607-117	Bubbler D-25	ND	No
WF007	39-0607-118	WF in Hall by B-35 (left)	ND	No
WF008	39-0607-119	WF across from A-5 (left)	ND	No
WF009	39-0607-120	WF in hall by Stage C-16 (right)	1.45	No

Action Level (AL) \geq 15.5 parts per billion (ppb)
 ND = None Detected; NR = Not Reported

Attachment L - Results Summary Lead in Water Sample

School Name: Dorothy L. Bullock School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
QC BLANK	39-0607-121	DI Blank	ND	No

Action Level (AL) ≥ 15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported