Attachment L - Results Summary Lead in Water Sample

School Name: Operations/Transportation Building

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-01	39-0620-01	Kitchenette sink	ND	No
WF-01	39-0620-02	Water fountain	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)
ND = None Detected; NR = Not Reported