
GLASSBORO PUBLIC SCHOOLS
DISTRICT UPDATE
MARCH 2020

All district buildings were Sprayed by GermNix with a hospital grade disinfectant, SDS sheets were provided and shared with each principal. They started Monday evening the 16th of March and finished the district on Wednesday. All buildings done including Beach and OPS/Transportation the grounds office and all busses.

AHERA 6-month inspections were done last week and I have the reports and will make sure each building gets their copy.

HIGH SCHOOL

Fire alarm panel up and running due to CPU board failure, not under warranty per George Duthie. A 24/7 fire watch was put in effect as soon as we were aware that the panel was not working.

I have reached out to LeeWay Electric to come back and find the CO Detectors ground fault issues since the buildings are empty and they can come at any time.

GIS

Tri County pest will be let into the building to do a bed bug monitoring, an issue we found out about last minute and right before school closure. Will keep everyone advised of their monitoring

BULLOCK

Tri County pest will be let into the building to do a bed bug monitoring, an issue we found out about last minute and right before school closure. Will keep everyone advised of their monitoring

RODGERS

Rodgers quarterly inspection and testing of the mercury off gassing was done on Tuesday the 24th, waiting for results, we also added another sample into the testing to meet DOE guidelines for air sampling these floors.

All work orders were completed as they arrived and signed off on by maintenance personnel