
**GLASSBORO PUBLIC SCHOOLS
DISTRICT PROJECT UPDATE
APRIL 2020**

District Wide Projects

High School

- Fire alarm and CO detectors all working now. All troubles cleared and issue was found for ground fault in Kitchen detector and fixed.
- Maintenance started filter changes in all units.
- Building checked on a regular basis

GIS

- Leak found in PAC building boiler room, backflow preventor not working, shut off water and turned off boilers and hot water for now.
- Issues with fire alarm, working on bringing a new company to service us better

BOWE

Bullock

- Staff still manning the building for lunch and laptop distribution.

Rodgers

- Gym floor testing done and levels well below State Guidelines.
- New quote given to continue with testing and to follow the State Guidelines for that as well.