
**GLASSBORO PUBLIC SCHOOLS
DISTRICT PROJECT UPDATE
JULY 2020**

District Wide Projects

High School

- Needs new oil lines for the chiller after season is over cost around \$10,000.00.
- High School Science Room A-139 roof top unit condensate pan overflowed due to a clog room being cleaned up and dehumidified to remove all moisture.

GIS

- Chiller giving us issues having a company come out and see if one of the compressors has failed.
- Roof top Honeywell controller failed had to replace, cost of around \$1600.00
- Brick Annex roof leaks and roof top condensate leaks.

Bowe

Bullock

Rodgers

- PO for CO Detectors in Rodgers Elementary issued to Franklin Alarm.

DISTRICT WIDE

- Job postings for 2 nighttime housekeepers/custodians to replace, Gaila Waiters and Robert Sample. One internal posting for night foreman at Rodgers due to transfer of night foreman to GIS
- Items coming in for marking district floors, walls, and entrances with social distancing guidelines.
- All work orders are being done in a timely fashion and all crews are moving along with building cleanings.

