

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

February 2023

District Wide Projects

High School

- New sinks for Home Economics have been ordered and are waiting for delivery in February. Ship date is now 2/17/2023. **Will be delivered within the next week or so.**
- Issue with smoking in boy's bathroom, looking into vape detectors, also re mapping to show proper location of bathroom on fire panel. Working with Franklin Alarm for HALO vape detectors as well as Chuck.
- New container ordered for the athletic program, softball, and baseball storage as well as soccer and field hockey to use for their equipment.

Bowe

- Two rooftops at Bowe under the emergency purchase, we have been notified they are delayed delivery is mid to late March. **Core Mechanical expects to have them by the 24th of March, installation tentatively is Easter Break 11th through the 14th.**
- Lockers installed in the classrooms and other areas still need numbers, and a few other items to finish the job. **Will finish during Spring Break.**
- Punch list and other work started to finish work in the new science labs.
- Staff have been painting hallways to spruce up the area around the new science classrooms and the building itself.
- Sewage ejectors pumps, one had failed due to being jammed. The second pump checked and working, and we were working on cost to replace one pump and rails that were broken for a while. The second pump failed due to jammed as well, Dormann and Central Septic out at Bowe to clean out pit and possibly replace pump. The pump was finally able to be removed around 11p on Monday night. Unfortunately, too many new parts were needed to be able to have pump in that night. School closed due to the no way to pump out sewage, and new pump in and running around noon on Tuesday, school cleared to be back the next day.
- Second pump to be installed with new rails during easter Break.
- Vandalism report attached.

Bullock

- Pricing new through the wall units for room C15 to replace two old units. NorthEast Mechanical awarded quote, unfortunately the units are 16-18 weeks out as of now. Ship date from manufacturer is **3/7/2023. Waiting for panels to come and then installation will happen.**
- Leak in the Art room, we believe due to gutter overflowing in the corner, roofer to come out to look at the gutters causing the issue. USA roofing will look at it this week. PO issued to fix gutter issues and stop walls from being saturated during a rainstorm.
- Price on replacing Nurse's office old and noisy air handler with Federal money, PO issued to Northeast Mechanical, installation to be during Easter Break.
- Working with Glassboro OEM to update all info for Bullock to be used as a shelter if necessary, working on occupancy and the new generator, for load testing and what else we can add to that circuit to help make it a better place of shelter.
- Vandalism report attached.

Rodgers

- Issue with one of the doors sticking by the flagpole. Fixed and looking for prices to replace both doors in that area. New upper plate to be installed by SJ Glass to fix issue with the other door.
- The latest testing of the mercury floor in Rodger's gym came back and we are still below state recommended levels for mercury vapor.

BEACH

OPS/TRANSPORTATION

DISTRICT WIDE

- rSchooltoday electronic work orders, 1481 work orders have been generated and approximately 41 still outstanding, most outstanding are from school heating issues and things needing put together and smaller repairs, work orders coming in daily.
- 6 containers now in the district for storage of items removed from GIS and other buildings. Containers will start getting emptied and return to vendor. **6 Containers have been or will be removed as we continue to clean them out of old items.**

- Working on Bond Referendum met with the public twice now to narrow down bond referendum projects. **The Bond Referendum was finalized with the stakeholders and Administration with 3 questions for the taxpayers and a total of about \$20 million dollars.**
- Working shorthanded, district wide and commend those who have stepped up to make sure we keep moving by helping wherever needed.
- A new 2023 F250 4x4 with snowplow has been ordered through a state contract with Winner Ford.

BULLOCK VANDALISM REPORT

Girl's 1st and 2nd grade bathroom stall door ripped off.

Soap is constantly being wasted and poured all over the bathroom floors, causing a slip hazard as well as a mess to clean up for the custodians.

Toilet broken and needed to be replaced in 3rd grade bathroom.

Paper towel dispensers in 3rd grade bathrooms needed fixing or replaced.

Toilet paper dispenser in 3rd grade girl's bathroom replaced.

4th and 5th grade bathrooms at least 4 soap dispensers torn off and replaced.

BOWE VANDALISM

REPORT

Flooding of boys' and girls' bathrooms, stuffing sinks with paper towels turning water on and leaving. New slow-release faucets installed.

Boys' 7th grade bathroom, boys removed pin that holds slow-release handle onto faucet.

Multiple exit lights knock down or loose around 15 times since school started.

Soap dispensers pulled off wall, broke etc. 5 times. But continues weekly.

8th grade boy's bathroom, 5 toilet paper dispensers broken. But continues weekly.

Electric cord on lights in bathrooms pulled off.

Graffiti on 8th grade girls and boy's bathrooms.

Urinals stuffed with paper towels and flooded.

Daily event toilet paper wrapped around the stalls; toilet paper use has doubled.

Ceiling tiles broken above urinals, kids climb on urinal and ouch the ceiling tiles out.

Tore off wall partition between urinals.

A box of gloves in media center used to clog bathroom toilets.

Around 15-20 ceiling tiles have been replaced in the bathroom.

Replaced or repaired 8 toilet paper dispensers.