

GLASSBORO PUBLIC SCHOOLS  
DISTRICT PROJECT UPDATE  
November 2023

District Wide Projects

**High School**

- High School Stadium, well pump needs to be replaced waiting on pricing. **13K for new well pump have reached out to other companies for pricing.**
- **Asbestos elbows in high school hallway to be removed, to fix issue with leaking pipe. PO in system for EDI and Shade Environmental for \$2,900.00. Done, Northeast plumbing looking at pipe leak and will price it out for us. \$5,912.00 to repair water needs to be shut off to building.**

**Bowe**

- Lockers installed in the classrooms and other areas still need numbers, and a few other items to finish the job. Will finish during Spring Break. **Still need to do some final work. Dan from FVHD is working to finalize the last of the work.**

**Bullock**

- **Issue with boy's bathroom and urine smell on floor. Trying to find something that will pull it out of the grout and remove the smell.**
- 

**Rodgers**

- **Nurse's office HVAC needs work compressor etc. \$6,500.00**
- **WJ Gross to look at overhang at Rodgers by the flagpole. Starting to look like it is falling apart. Gross put up supports to the overhang.**
- **Two broken coils in rooms A6 AND A4. Northeast to replace with OEM \$18,452.00**

**BEACH**

**OPS/TRANSPORTATION**

**DISTRICT WIDE**

- rSchooltoday electronic work orders, 1974 work orders have been generated and approximately 43 still outstanding, most outstanding are from school heating issues and things needing put together and smaller repairs, work orders coming in daily.
- Fire Inspection handled by Logan Township; we are continuing to fix all issues and work with them on a few other issues where PO's will need to be issued to fix some items. **Given extension to finish some smaller issues as well as the sprinkler testing and updating needed to be done. PO issued to ABJ for sprinkler inspection for August 7-10<sup>th</sup>, Logan Fire Official has been informed. Fire lanes curbs to be painted inhouse to save money, quote was over \$7,000.00**
- **ABJ fire sprinklers issued PO for repairs and upgrades to NFPA 25 standards.**