

GLASSBORO PUBLIC SCHOOLS
DISTRICT PROJECT UPDATE

February 2024

District Wide Projects

High School

Description	Actions	Status
High School Stadium, well pump needs to be replaced waiting for pricing.	<ul style="list-style-type: none"> • 13K for new well pump • Reached out to other companies for pricing. 	Open
Overhang in front of high school, light not working due to a dead short.	<ul style="list-style-type: none"> • Northeast Electric is looking into the issue. • Lights have been fixed. 	Completed
Leaks in guidance are by copier and conference room due to last storm and high winds.	<ul style="list-style-type: none"> • Looking for a roof contractor. 	Open
Fire alarm went off in the building.	<ul style="list-style-type: none"> • FD Responded. • Building evacuated 	Information Only

Bowe

Description	Action	Status
Several leaks in usual places, due to heavy rains	<ul style="list-style-type: none"> • Looking for a roof contractor 	Open
A burning smell in the vicinity next to the kitchen.	<ul style="list-style-type: none"> • FD was called. • Nothing was found 	Information Only
AHU-4 is down.	<ul style="list-style-type: none"> • Parts are ordered; 1-2 weeks out. 	Work in progress
ABJ sprinkler, Glassboro water and Northeast plumbing under my supervision.	<ul style="list-style-type: none"> • Corrected all the deficiencies in the fire sprinkler system. • All paperwork was submitted by email to Logan Fire Inspector Hall. 	Completed
Outside perimeter lights, half of the building lights not working.	<ul style="list-style-type: none"> • Northeast Electric is looking into the issue. • Bad Photocell • Lights have been fixed 	Completed
Last weekend, the gym floor was scrubbed. This was done with the help of the HS custodian team. Sealed the floor with a special sealer.	<ul style="list-style-type: none"> • A lot of wax was removed. • In two weeks, we plan to scrub the floor one more time. • Seal the floor with a special sealer 	Open

Bullock

Description	Actions	Status
Dylan Clark went for his fingerprints on 2/6/24.	<ul style="list-style-type: none">• If the fingerprints are satisfactory, he will start his employment on 2/16/24.• He will be replacing Nelson.	Open
Roof leak in classroom C-36 due to heavy rain	<ul style="list-style-type: none">• Looking for a roof contractor.	Open
ABJ Sprinkler and Glassboro water are scheduled to work on 2/10/24.	<ul style="list-style-type: none">• To correct the deficiencies in the sprinkler system.• Two valves need to be rebuilt.	Open

Rodgers

Description	Actions	Status
Two broken coils in rooms A4 and A6.	<ul style="list-style-type: none">• Northeast Mechanical ordered the coils.	Open
Issues with rooms overheating Northeast Mechanical looking into the make-up air units not cooling the building properly.	<ul style="list-style-type: none">• Bad sensor was replaced.• The make-up air units are working properly now.	Completed
WJ Gross look at the overhang by the pole, starting to look like it is falling apart	<ul style="list-style-type: none">• WJ Gross put up support to the overhang.	Open
Classroom D-3 right after the snowstorm and rain the room started to get an unpleasant mildew odor.	<ul style="list-style-type: none">• We contacted EDI, our environmental company.• They took samples of air.• Results does not appear to be airborne mold conditions in classroom D3.• Over the weekend we followed the recommendations of EDI.• Treated the classroom with Fiber lock shockwave and kilz mildew primer.• We installed 2 HEPA filters and 3 dehumidifiers.• The smell has faded away.• We will continue to monitor the classroom for two weeks.	Work in progress

Beach

Description	Action	Status
Leak in corner of BA's office from recent storm.	<ul style="list-style-type: none">Looking for a roof contractor.	Open
Server room mini split system down and not repairable. The second large HVAC unit has a pan leak which has been causing flooding in the area.	<ul style="list-style-type: none">New pan ordered; this unit is large enough to keep the server room cool.Pan has been replaced, no more leaks.	Completed

Ops/Transportation

Description	Action	Status
<ul style="list-style-type: none">Mr. Booth recommended purchasing more cameras for the far end of the bus yard and maintenance garage for better coverage.	<ul style="list-style-type: none">	Open

District Wide

Description	Status
<ul style="list-style-type: none">I would like to acknowledge the hard work of my entire team during the snowstorm.	Information only
<ul style="list-style-type: none">Ryan Catania Resigned his position as groundskeeper, his last day will be February 16, 2024.	Information only
<ul style="list-style-type: none">I would like to thank the Glassboro water department for their assistance helping us to complete our fire sprinkler system repairs.	Information only