GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

JULY 2024

District Wide Projects

High School

Description	Actions	Status
Culinary room Three sink compartment	FVHD Architects	Open
needs to be installed, also a grease trap.		
High School cooling tower. Two strainers	Northeast Mechanical	Completed
need to be replaced	Replaced strainers	
Leaks in guidance are by copier and	 Work will be done in- 	Work-in
conference room due to last storm and	house	progress
high winds		
Music, Choir and Band rooms VCT Tiles need	A&J Flooring	Open
to be replace		
Trane Chiller went down, control issues	Called Northeast	Completed
	Mechanical and Bradley	
	Siocchetti,	Onen
Cooling Tower keeps going on Fault 3 "Dev	Northeast Mechanical	Open
overtemp" ABB Drive cooling fan is bad		
Music, Choir and Band rooms were	In-house Custodians	Completed
painted		
During the annual fire inspection 2024	 Waiting for quotes 	Open
inspector Hall found a letter that states	 Also, I requested an 	
the fire pump needs to be repair or replace	extension to perform the	
	repair of the fire pump	
Parking Lines need to be re-painted and	 In-house by Grounds and 	Open
number	Maintenance teams	

Bowe

Description	Action	Status
Several leaks in usual places, due to heavy rains	 Work will be done in- house 	Work in progress
Classrooms C123 & C137 VCT Tiles need to be replace	A&J Flooring	Open
Replace 7 season 4 RTU's	All Coast	Work in progress

Bullock

Description	Actions	Status
Mid-shift Mr. Tyler Logn	 Waiting for background check and board approval 	Open
Roof leak in classroom C-36 due to heavy rain	 Work will be done in- house 	Work in progress
Parking Lines need to be-repaint	 In-house grounds and maintenance teams 	Open
Wheelchair ramp in the back of the school needs to be repaired.	Waiting for quotes	Open

Rogers

Description	Actions	Status
The following classrooms have a bad	 Northeast 	Completed
freeze stat and fan cycle control : A1-A10	Mechanical	
Cafeteria one of the Unit Ventilator the coil	 Northeast 	Open
is broken. Waiting for a quote	Mechanical	
WJ Gross look at the overhang by the pole	WJ Gross put up	Work in
	support to the	progress
	overhang.	
Gym floor will be replaced	 Contractor 	Open
Cafeteria Unit 3 Ventilator coil	 Northeast 	Open
broke needs to be replace.	Mechanical	
 Cafeteria Unit 1 needs new 	 Northeast 	Open
compressor	Mechanical	
New Playground was installed	•	Work in
		progress

Beach

Description	Action	Status
Leak by HR's office from recent rain.	Work will be done	Completed
	in-house.	

Ops/Transportation

Description	Action	Status
Recommended purchasing more	•	Work in
cameras for the far end of the bus yard		progress
and maintenance garage for better		
coverage.		

District Wide

Description	Status
 General Chemical came to the high school to train our 	Information only
housekeepers and custodians on how to stripper and wax floors.	
I would like to thank the Borough of Glassboro for helping with	Information
the removal of two three that came down on the back of Bowe	Only
school during the storm.	
 Total Work orders 1800, Open 25 as of 5/31/2024 	Information only