

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

January 2026

District Wide Projects

High School

Description	Actions	Status
New roof leak	<ul style="list-style-type: none"> • In house 	Work in progress
New LED light fixtures are being installed throughout the entire parking lot and in several classrooms	<ul style="list-style-type: none"> • In House • Parking lights and around the building has been updated to LED 	Work in progress
Classroom D28 – The Cooper Union: A coupling/union in the heating system failed and came loose, resulting in water discharge. The fire alarm system was activated, and the Fire Department responded. Water affected Classroom D28 and the adjacent hallway	<ul style="list-style-type: none"> • Work was done in-house • Replaced copper union and refilled entire heating system left the GHS at 1:30am. 	Completed

Bowe

Description	Action	Status
Gym closet was convert to an office that needs electrical outlet	<ul style="list-style-type: none"> • In-house • new electrical outlet ran from the electrical panel to the office. 	Completed
Science lab	<ul style="list-style-type: none"> • In-house • new electrical outlet ran from the electrical panel to the office. 	Work in progress
Domestic hot water tank, keeps going in safety mode.	<ul style="list-style-type: none"> • In-house • Parts were ordered 	Completed
Potholes	<ul style="list-style-type: none"> • In house • Monitoring until we have a permanently solution 	Work in progress

Bullock

Description	Actions	Status
Walking Freezer Fan motor blower	<ul style="list-style-type: none">• In house• Order motor blower	Completed
Classrooom B60 need a new moto blower for unit ventilator	<ul style="list-style-type: none">• In-house• ordered	Completed
By hollybush some trees need to be taking down.	<ul style="list-style-type: none">• In house• Grounds crew	Completed
Boilers were down due to a bad combustion fan motor on 11/30/25 Maintenance team responded to emergency	<ul style="list-style-type: none">• In house• ordered	Completed

Rodgers

Description	Actions	Status
Cafeteria Unit 1 needs new compressor	<ul style="list-style-type: none">• Waiting for quote	Open
Cafeteria Unit 2 needs to be replaced	<ul style="list-style-type: none">• Waiting for quote	Open
On November 20, a second broken coil was discovered in room A15. Fortunately, there was no water damage due to the quick response of our housekeeper. We attempted to repair the coil in place, but there were too many holes, making it beyond repair. Switch to a new vendor	<ul style="list-style-type: none">• Northeast Mechanical• Coil has been ordered 6 to 8 weeks lead time	Work in Progress
On December 11, 2024 another broken coil room A13 switch to a new vendor	<ul style="list-style-type: none">• Northeast mechanical• Coil has been order 6 to 8 weeks lead time	Work in progress
Part of the playground fence needs to be replaced	<ul style="list-style-type: none">• I house• Getting prices• ordered	In progress
November 24, 2025: An underground heating distribution pipe serving Classrooms B3, B5, B7, and the cafeteria was identified as leaking. The pipe is in a deteriorated condition. The affected	<ul style="list-style-type: none">• Quote• Quote has been approved• Work to start on 1/2/2026	Work in progress

heating zone has been isolated from the system to prevent further impact.		
---	--	--

Beach

Description	Action	Status
New LED Light fixtures are being installed in the entire Beach Building	<ul style="list-style-type: none"> • Work will done in house 	Completed

Ops/Transportation

Description	Action	Status
New LED Light fixtures are being installed in the entire OPS Office and Grounds Shop	Work will done in house	Completed
Recommended purchasing more cameras for the far end of the bus yard and maintenance garage for better coverage.	<ul style="list-style-type: none"> • Cat6 cable was run in house . 	Completed

District Wide

Description	Status
<ul style="list-style-type: none"> • I would like to acknowledge the dedication and commitment of my entire team over the past year. They consistently go above and beyond their assigned duties. I can confidently say that I am proud to work with such an exceptional team, and together we are making a meaningful difference within the school district. I look forward to another successful year in 2026. • I would also like to acknowledge the help of our district mechanics, Charlie and Dan, during the snowstorm. They jumped in to replace a flat tire on a dump truck loaded with two tons of salt. Thanks to their quick response and hard work, they 	Informational only

were able to get the truck back in service so it could continue salting parking lots throughout the district.	
• Total Work orders this month 30 as of 1/8/2026	Information only