

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

April 2026

District Wide Projects

High School

Description	Actions	Status
New roof leak	<ul style="list-style-type: none"> In house 	Work in progress
New LED light fixtures are being installed throughout the entire parking lot and in several classrooms	<ul style="list-style-type: none"> In House Parking lights and around the building has been updated to LED 	Work in progress
Boiler #2 Circulation pump leaking from packing	<ul style="list-style-type: none"> Maintenance team removed pump sent pump to be repacking (Seal) 	Work in progress
Classroom D28 Standalone HVAC Unit Malfunctioning	<ul style="list-style-type: none"> LGB Contractor Bad motor Bad transformer 	Completed
DEP of New Jersey Violation Year 2009	<ul style="list-style-type: none"> Architect FVHD 	Work in progress

Bowe

Description	Action	Status
Science lab	<ul style="list-style-type: none"> In-house new electrical outlet ran from the electrical panel to the office. 	Completed
Potholes	<ul style="list-style-type: none"> In house Monitoring until we have a permanently solution 	Work in progress
New Leak, Classrooms, hallaways, Gym, Art room	<ul style="list-style-type: none"> In-house 	Work in progress
	<ul style="list-style-type: none"> 	

Bullock

Description	Actions	Status
School office ceiling unit making noise	<ul style="list-style-type: none"> Remove blower fan from unit , sent out to replaced bearings and shaft 	Work in progress
School Office roof leak	<ul style="list-style-type: none"> In house band aid 	Open
Main entrance walk way two glass window broke do to snow fall from roof and broke the glasses	<ul style="list-style-type: none"> Remove one broken glass. Waiting to get an estimate 	Work in progress

Rodgers

Description	Actions	Status
Cafeteria Unit 1 needs new compressor	<ul style="list-style-type: none"> Waiting for quote 	Open
Cafeteria Unit 2 needs to be replaced	<ul style="list-style-type: none"> Waiting for quote 	Open
Boiler #2 Heat exchanger(vessel) is leaking	<ul style="list-style-type: none"> LGB Contractor Looking to see if it is still under warranty Looking into options 	Open
School Office copier room roof leak, Hallways	<ul style="list-style-type: none"> Due to the Snow In house band aid 	Open
Cafeteria roof leak	<ul style="list-style-type: none"> Monitoring 	Open
Hallway outside Boiler room roof leak	<ul style="list-style-type: none"> Monitoring 	Open
Hallway outside cafeteria roof leak	<ul style="list-style-type: none"> Monitoring 	Open

Beach

Description	Action	Status
New Office for new Administrator	<ul style="list-style-type: none"> Building a new office (Maintenance and Ground teams) 	Work in progress

Ops/Transportation

Description	Action	Status
The access road requires repair due to an increasing number of potholes.	Monitoring: I am scheduled to meet with Mr. Chip (Borough) to discuss the possibility of his assistance with interim remediation efforts.	Open

District Wide

Description	Status
<ul style="list-style-type: none"> FD to GHS False alarm. 	Informational only
<ul style="list-style-type: none"> FD Annual Inspection (2026) The inspection of the entire School District identified deficiencies at the Beach Building and Rodgers School. Repairs are currently in progress, 	Informational only
<ul style="list-style-type: none"> Total Work orders this month 20 as of 4/13/2026 	Information only

Referendum

Architects:	Walking Rodgers School, Bullock; Bowe School; GHS and Ops Building. Looking at doors	
Gym architect and Contractor	Walking Bowe Roof	