

# GLASSBORO PUBLIC SCHOOLS

## DISTRICT PROJECT UPDATE

June 2026

### District Wide Projects

#### High School

Description	Actions	Status
New roof leak	<ul style="list-style-type: none"> <li>Band aid</li> </ul>	Work in progress
New LED light fixtures are being installed throughout the entire parking lot and in several classrooms	<ul style="list-style-type: none"> <li>In House</li> <li>Parking lights and around the building has been updated to LED</li> </ul>	Completed
Upgrade of gas line that feeds gas meter outside boiler room	<ul style="list-style-type: none"> <li>South Jersey Gas 5/16/2026</li> </ul>	Completed
	<ul style="list-style-type: none"> <li></li> </ul>	
DEP of New Jersey Violation Year 2009	<ul style="list-style-type: none"> <li>Architect FVHD</li> </ul>	Work in progress

#### Bowe

Description	Action	Status
	<ul style="list-style-type: none"> <li></li> </ul>	
Potholes Possibility of repaving the drop off area.	<ul style="list-style-type: none"> <li>Paving Plus</li> <li>Monitoring until we have a permanently solution</li> </ul>	Open
New Leak, Classrooms, hallways, Gym, Art room	<ul style="list-style-type: none"> <li>Summer Work (Referendum)</li> </ul>	Work in progress
	<ul style="list-style-type: none"> <li></li> </ul>	

#### Bullock

Description	Actions	Status
School Office roof leak	<ul style="list-style-type: none"> <li>In house band aid</li> </ul>	Completed

## Rodgers

Description	Actions	Status
Cafeteria Unit 1 needs new compressor	<ul style="list-style-type: none"><li>• Waiting for quote</li></ul>	Open
Cafeteria Unit 2 needs to be replaced	<ul style="list-style-type: none"><li>• Waiting for quote</li></ul>	Open
Boiler #2 Heat exchanger(vessel) is leaking	<ul style="list-style-type: none"><li>• LGB Contractor</li><li>• Looking to see if it is still under warranty</li><li>• Looking into options</li></ul>	Open
School Office copier room roof leak, Hallways	<ul style="list-style-type: none"><li>• Summer Work (Referemdum)</li></ul>	Work in progress
Cafeteria roof leak	<ul style="list-style-type: none"><li>• Summer Work (Referemdum)</li></ul>	Work in progress
Hallway outside Boiler room roof leak	<ul style="list-style-type: none"><li>• Summer Work (Referemdum)</li></ul>	Work in progress
Hallway outside cafeteria roof leak	<ul style="list-style-type: none"><li>• Summer Work (Referemdum)</li></ul>	Work in progress

## Beach

Description	Action	Status
New Office for new Administrator	<ul style="list-style-type: none"><li>• Building a new office (Maintenance and Ground teams)</li><li>• New door was ordered</li></ul>	Completed
Open a passageway from small conference room to main office	<ul style="list-style-type: none"><li>• Work in House</li></ul>	Open

## Ops/Transportation

Description	Action	Status
Paving Access Road	<ul style="list-style-type: none"><li>• Paving Plus</li></ul>	Open

**District Wide**

<b>Description</b>	<b>Status</b>
• FD to GHS False alarm.	Informational only
• One of our maintenance team quit in May 29, 2026.	Informational only
• Total Work orders this month 40 as of 6/8/2026	Information only
• One Housekeeper was hired for Bowe school • One Housekeeper was hired for midshift Bullock School	Information only

**Referendum**

USA Roofer and EDI	The roofer returned to Rodgers with EDI Environmental to collect additional samples	Informational only
FVHD , Civil Engineer , Mr Lynch and Mr Olivo	Conducted a site walk of the football stadium, softball field, baseball field, soccer field, and hockey field to evaluate field drainage conditions and identify any areas requiring improvement. Also assessed the feasibility of installing a new irrigation well to support watering needs for all athletic fields.	Informational only