

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

September 2026

District Wide Projects

High School

Description	Actions	Status
New roof leak	Band aid	Work in progress
DEP of New Jersey Violation Year 2009	Architect FVHD	Work in progress
Hot water flex Connector leaking outside cafeteria hallway	- Northeast plumbing - Parts were ordered	Work in progress

Bowe

Description	Action	Status
Gym Roof replacement	Referendum	Work in progress
Gym Painting	Referendum	Complete
Gym new Wood floor	Referendum	Work in Progress
Gym new Bleachers	Referendum	Work in progress
Gym wall padding	Referendum	Work in progress

Bullock

Description	Actions	Status
Classrooms B51 & B24 Complains of air quality	Called EDI to take samples of the air in the classrooms	Work in progress
Teacher Lounge bad motor	In House waiting for the motor to arrive	Open

Rodgers

Description	Actions	Status
Cafeteria Unit 1 needs new compressor	Waiting for quote	Open
Cafeteria Unit 2 needs to be replaced	Waiting for quote	Open
Boiler #2 Heat exchanger(vessel) is leaking	Just receive a quote	Open
School Office copier room roof leak, Hallways	Summer Work (Referendum)	Work in progress
Hallway outside Boiler room roof leak	Summer Work (Referendum)	Work in progress
Hot water heater bad gas valve	- Northeast Mechanical - Replaced gas valve	Completed
Boiler room gate valve need to be replace	- Northeast Plumbing - Parts were ordered	Work in Progress
Classroom A3 Broken heating coil	- Isolate the valve - Waiting for estimates	Open

Beach

Description	Action	Status
New Roof (Replacement)	Referendum	Work in progress

Ops/Transportation

Description	Action	Status

Mitcho ECC

Description	Action	Status

District Wide

Description	Status
•	