

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

August 2026

District Wide Projects

High School

Description	Actions	Status
New roof leak	Band aid	Work in progress
DEP of New Jersey Violation Year 2009	Architect FVHD	Work in progress
Hot water flex Connector leaking outside cafeteria hallway	- Northeast plumbing - Parts were ordered	Completed

Bowe

Description	Action	Status
Gym Roof replacement	Referendum	Work in progress
Gym Painting	Referendum	Work in progress
Gym new Wood floor	Referendum	Work in Progress
Gym new Bleachers	Referendum	Work in progress
Gym wall padding	Referendum	Work in progress
Gym Scoreboard	Referendum	Work in progress

Bullock

Description	Actions	Status
Classrooms B51 & B24 Complains of air quality	Called EDI to take samples of the air in the classrooms	Completed
Teacher Lounge bad motor	In House waiting for the motor to arrive	Completed

Rodgers

Description	Actions	Status
Cafeteria Unit 1 needs new compressor	Waiting for quote	Open
Cafeteria Unit 2 needs to be replaced	Waiting for quote	Open
Boiler #2 Heat exchanger(vessel) is leaking	Just receive a quote	Open
School Office copier room roof leak, Hallways	Summer Work (Referendum)	Work in progress
Hallway outside Boiler room roof leak	Summer Work (Referendum)	Work in progress
Hot water heater bad gas valve	- Northeast Mechanical - Replaced gas valve	Completed
Boiler room gate valve needs to be replaced	- Northeast Plumbing - Parts were ordered	Completed
Classroom A3 Broken heating coil	- Isolate the valve - Waiting for estimates	Open
Classroom D6 broken coil	- Isolate the valve - Waiting for estimate	Open
Classroom D3 Complains air quality	Caled EDI to take samples of the air in the classroom	Open

Beach

Description	Action	Status
New Roof (Replacement)	Referendum	Work in progress

Ops/Transportation

Description	Action	Status

Mitcho ECC

Description	Action	Status
	•	

District Wide

Description	Status
•	