# GLASSBORO PUBLIC SCHOOLS GLASSBORO, NEW JERSEY

#### February 7, 2018

#### MAINTENANCE DEPARTMENT REPORT

The following tasks were completed by our maintenance staff during the month:

**Glassboro High School** 

- 1. Checked for piping leaks above ceiling in A-107.
- 2. Ran the standby generator and checked all emergency lighting.
- 3. Replaced the ceiling tile for the occupancy sensor in A-107.
- 4. Troubleshot no heat from fan coil #8. Coil frozen.
- 5. Began to remove the heat coil from fan coil #8.
- 6. Began to make repairs to the heat pipe couplings above ceiling in A-107.
- 7. Received initial training on the new ATC system.
- 8. Replaced the dielectric union gaskets in the heat pipe above ceiling in A-107.
- 9. Worked with South Jersey Gas Company trying to identify a natural gas smell complaint.
- 10. Replaced one lamp in the back canopy lights.
- 11. Checked gym air handlers for no heat. Contacted installation contractor for service.
- 12. Ordered parts for one heating boiler.
- 13. Checked girl's locker room for sewer odor. Nothing found.
- 14. Worked with the ATC contractor on temperature issues.
- 15. Repaired two urinal flush valves in the boy's lavatory by A-108.
- 16. Replaced one ceiling tile in the main office. Could not find source that stained the tile.
- 17. Repaired the soap dispenser fill for the sink in the main hall boy's lavatory.
- 18. Repaired the door closer on the boy's side gym entrance doors.
- 19. Repaired the flush valve for the toilet in the girl's lavatory by A-107.
- 20. Replaced the flush valve controller in the boy's lavatory by A-108.
- 21. Replaced the flush valve controller in the gender neutral lavatory by the media center.
- 22. Replaced the lamp in the wall pack fixture facing the football field.

- 23. Repaired the door handle for room A-134.
- 24. Checked for a roof leak over the girl's locker room.
- 25. Replaced the light switch in the boy's locker room to a key switch.
- 26. Replaced the photocell on the exterior light near A-138.
- 27. Replaced the lamp in the wall pack light near the board office.
- 28. Repaired one custodial vacuum cleaner.
- 29. Repaired the lock on the guidance office doors.
- 30. Checked the operation of the bleachers in the gym on the boy's side.
- 31. Replaced one light ballast in room A-102.
- 32. Checked the outlet in the kitchen office and tested.
- 33. Changed out the door lock for the staff lavatory across from A-107.
- 34. Re hung the sprinkler head cabinet and fire extinguisher in the boiler room.
- 35. Repaired the center bar floor cleat for the back entrance doors.
- 36. Put the ceiling back up in room A-107 after pipe repairs.
- 37. Repaired the front entrance doors.
- 38. Repaired the lock on the girl's side gym exterior doors.
- 39. Repaired the light in the back stage paint sink room.
- 40. Replaced the counter in the school store.
- 41. Repaired the door lock for room A-134.

Intermediate School

- 1. Checked for above ceiling leaks in room 202.
- 2. Checked boilers for heat. Found new ATC controls were not controlling modulation properly.
- 3. Ran the stand by generator and checked emergency lights and exit signs.
- 4. Reset the freeze stat for room 206.
- 5. Replaced the drive belt for the air handler for room 114.
- 6. Restored heat in room 307.
- 7. Replaced the dielectric union gaskets for the above ceiling heat pipes in room 202.
- 8. Restored heat to rooms 306 and 307.
- 9. Cleared a clogged drain for the first floor custodial closet sink.
- 10. Cleared a clogged toilet in the girl's locker room.
- 11. Replaced the ceiling in room 202 after pipe repairs.
- 12. Replaced floor tiles near room 116. Total 12 tiles replaced.
- 13. Restored heat to the cabinet heater outside of the girl's locker room.
- 14. Repaired the kick plate on one gym exit door.
- 15. Repaired the wheels on the custodian's hand truck.
- 16. Replaced light tubes in the main office.
- 17. Repaired one light fixture cover in the Assistant Principal's office.
- 18. Repaired the drive shaft for the unit ventilator in room 213.

## Thomas Bowe School

- 1. Checked the rooftop HVAC units every day and reset as needed.
- 2. Reset the burner for MZ-7.
- 3. Replaced the burner modulation motor and interface module on MZ-10.
- 4. Worked with outside contractor on MZ-2.
- 5. Tested the stand by generator and check emergency lights and exit signs.
- 6. Replaced the batteries on the automatic floor machine.
- 7. Reset the burner for MZ-11.
- 8. Worked on burner and supply fan relays for MZ-7.
- 9. Reset the burner for MZ-10.
- 10. Replaced the light cover on the fixture outside the kitchen door.
- 11. Temporarily repaired one bleacher step in the gym. Tread was broken off.
- 12. Replaced one lamp in the wall pack closest to the cafeteria.
- 13. Repaired the lock for the 4<sup>th</sup> grade girl's lavatory.
- 14. Repaired four urinals and one toilet in the 5<sup>th</sup> grade boy's lavatory.
- 15. Repaired a leak in the  $6^{th}$  grade boy's lavatory.
- 16. Replaced one vacuum breaker for a toilet in the 5<sup>th</sup> grade girl's lavatory.
- 17. Replaced the lamp in the exterior light near the music room.
- 18. Repaired one custodial vacuum cleaner.
- 19. Re hung the exit sign near room C-137. Sign was vandalized.
- 20. Repaired the door lock for the main office and the SRO's office.
- 21. Repaired a leak on one toilet in the 4<sup>th</sup> grade girl's lavatory.
- 22. Repaired the door latch on the door for the storage closet near the art room.
- 23. Sealed up an area in the wall of the main entrance vestibule.
- 24. Ordered and received replacement keys for the roll up door in the kitchen.

J. Harvey Rodgers School

- 1. Removed the unit ventilator coil from room B-7 to be repaired.
- 2. Worked on heat issues in rooms A-2, A-4, A-7 and A-8.
- 3. Cleaned the bearing for the unit ventilator in room A-4.
- 4. Repaired one custodial vacuum cleaner.
- 5. Reinstalled the coil for room B-7 and got unit operational.
- 6. Repaired the sink stopper in the kitchen.
- 7. Restored heat in the resource room.
- 8. Patched holes that were created with the running of the new heat supply in the B-wing.
- 9. Replaced the lamp in the canopy fixture outside between rooms A-5 and A-5.
- 10. Readjusted the swing door in the main office.
- 11. Checked all emergency lights.
- 12. Restored heat in room A-8.
- 13. Repaired the cabinet door in room A-8.
- 14. Replaced the lamp in the fixture outside of the all purpose room.
- 15. Repaired the exit doors going out to the bus area.

Bullock School

- 1. Worked on restoring heat in the kitchen. Problem was that the kitchen staff did not have the air make up unit powered up.
- 2. Reset the freeze stat for rooms C-37 and C-40.
- 3. Reset the unit in room D-15.
- 4. Tested the stand by generator and checked exit signs and emergency lights.
- 5. Reset the freeze stat for rooms A-9 and A-14.
- 6. Removed #1 boiler circulating motor / pump assembly for overhaul.
- 7. Repaired a leaking valve in the C-wing boy's lavatory.
- 8. Reinstalled #1 boiler circulating motor / pump assembly and restarted the boiler.
- 9. Worked on a water leak for the unit ventilator in C-37.
- 10. Began to reinstall the heat coil in room A-21.
- 11. Replaced the vacuum breaker for the toilet in the kitchen lavatory.
- 12. Remounted the soap dispenser in the  $2^{nd}$  grade boy's lavatory.
- 13. Repaired the front doors so they would latch. Threshold had heaved from ice.
- 14. Repaired one custodial vacuum cleaner.
- 15. Changed out six lock cores from the construction core to permanent core.
- 16. Repaired one exterior gym entrance door.
- 17. Replaced the lockset for the stage door.
- 18. Replaced two drive belts on rooftop exhaust fans for the kitchen.
- 19. Repaired the door handle for the media center.
- 20. Replaced the drive motor and drive bearing for the unit ventilator in room C-40.

## **Board Office**

- 1. Tested the emergency generator.
- 2. Rewired one canopy light fixture.
- 3. Rebuilt the toilets in the female lavatory.

## Transportation Garage

No repairs to report for the month.

## Brick Annex

- 1. Cleared a clogged toilet in the girl's lavatory.
- 2. Repaired a desk drawer in room #4.
- 3. Replaced two lamps in the exterior wall pack lights.

# **Operations Office**

1. Cleared clog in driver's room lavatory.

## Wood Annex

No repairs to report for the month.

The following assignments were completed by our Ground's staff:

- 1. Policed up the grounds at all facilities for trash.
- 2. Picked up and delivered inner office mail district wide every day.
- 3. Delivered custodial supplies to the schools as requested.
- 4. Handled snow and ice events with plowing and salting.
- 5. Began prepping the baseball / softball fields for spring sports practices.