GLASSBORO PUBLIC SCHOOLS GLASSBORO, NEW JERSEY

March 9, 2018

MAINTENANCE DEPARTMENT REPORT

The following tasks were completed by our maintenance staff during the month:

Glassboro High School

- 1. Repaired the rope and pulley system on the stage curtains.
- 2. Ran the standby generator and checked all emergency lighting.
- 3. Replaced the ignitor injection assembly on Boiler #1.
- 4. Cleaned boiler room.
- 5. Cleaned all three heating boilers and two domestic hot water boilers.
- 6. Received owner training on the new BARD classroom HVAC units.
- 7. Received owner training on the Carrier air handlers in the gym, cafeterias and media center.
- 8. Received owner training on the Aerco boilers.
- 9. Received owner training on the Aaon air handlers for the band room, choral room, orchestra room, auxiliary gym and science rooms.
- 10. Received owner training on the single and dual temperature pumps and VFD's.
- 11. Re-attached the cover on one smoke detector in the gym.
- 12. Received owner training on the new fan coil units.
- 13. Replaced the photocell on the science wing wall pack light.
- 14. Replaced six light tubes and one ballast in the boy's side gym foyer.
- 15. Remounted the stall lock for the gym office lavatory.
- 16. Hung new signs in the gym.
- 17. Tightened the bolts on one front door closer.
- 18. Remounted the cleat holding the center bar for the C-wing entrance doors.
- 19. Installed a TV mount, TV and ran H.D. cable in the main office foyer.
- 20. Repaired the dryer vent door in the boy's locker laundry room.
- 21. Repaired loose floor tiles near A-138.
- 22. Hung a new light fixture in the Nurse's office.
- 23. Repaired the door threshold at the boy's side gym entrance doors.
- 24. Repaired the bulletin board in the hall near room A-107.

- 25. Remounted one sink in the boy's C-wing lavatory that was ripped from the wall.
- 26. Repaired the flush valve for the principal's office lavatory.
- 27. Replaced the lamp in the exterior light near the gym.
- 28. Replaced lock cores in two storage room doors.
- 29. Installed three additional CO detectors in the auxiliary gym.
- 30. Repaired the door handles / locks on the girl's side gym entrance doors.
- 31. Replaced three ceiling tiles in room C-110.
- 32. Replaced four light tubes in the Nurse's office.
- 33. Repaired a roof leak over the principal's office.
- 34. Replaced one flush valve in the girl's lavatory near A-107.
- 35. Sealed one abandoned vent pipe on the roof near the main office.
- 36. Repaired the door locks going into the TV studio.
- 37. Replaced the lock for the inner door in the nurse's office.
- 38. Repaired the A-wing front hall security gate.
- 39. Repaired the throw pins in nine classroom doors.
- 40. Repaired one chair in the media center office.
- 41. Replaced the ballast and lamp in the pole light behind C-wing.
- 42. Repaired the latch for the exterior gym doors.
- 43. Unclogged one toilet in the girl's locker room.
- 44. Replaced the key for the hallway security gates.

Intermediate School

- 1. Restored heat in room 307.
- 2. Checked room 205 for overheating issue.
- 3. Ran the stand by generator and checked emergency lights and exit signs.
- 4. Began changing filters in unit ventilators.
- 5. Replaced the actuator on the heat control valve in room 307.
- 6. Completed changing filters in unit ventilators.
- 7. Replaced the actuator on the heat valve for room 205.
- 8. Cleared the sink drain in the basement custodial sink.
- 9. Replaced a broken light switch in room 108.
- 10. Replaced a broken light switch in room 301.
- 11. Replaced the lamps in the light near the kitchen stairway.
- 12. Tightened the bolts on one basketball hoop in the gym.
- 13. Repaired the door closer for the locker room door on the boy's side of the gym.
- 14. Repaired the lock on the principal's desk.
- 15. Replaced one ballast and two tubes in the hall next to the media center.
- 16. Repaired the window shade in room 207.
- 17. Replaced the office door for the nurse to an intruder function lock.
- 18. Repaired the door lock for the back door in the nurse's office.
- 19. Repaired the round light over the back door ramp.
- 20. Replaced the vacuum breaker for the toilet in the nurse's office.

- 21. Installed hasps and locks on all circuit breaker panels.
- 22. Repaired the door frame for the door at the top of the science wing staircase.
- 23. Repaired the door lock for the guidance office.
- 24. Repaired the door for room 104.
- 25. Repaired the door frame for the second floor staff lavatory.
- 26. Changed the lock for the main office door.
- 27. Installed a lever handle lock set for the kitchen basement door.
- 28. Installed a lever handle lock set for the south side basement door.
- 29. Re attached wire mold to the wall in the south side stairwell.
- 30. Installed eight light tubes and one ballast in the basement.
- 31. Unclogged one toilet in the girl's locker room.
- 32. Replaced the lamps in the round exterior light over the gym doors.
- 33. Repaired the "S" hooks for the projection screen in room 201.
- 34. Replaced the drive belt in the air handler for the nurse's office.

Thomas Bowe School

- 1. Checked the rooftop HVAC units every day and reset as needed.
- 2. Replaced all older exit signs with new LED signs. Total of eighteen signs.
- 3. Cleaned the filters and replaced aerators for the kitchen hand wash sinks.
- 4. Cleared a clog in the kitchen sewer line.
- 5. Tested the stand by generator and check emergency lights and exit signs.
- 6. Installed new lever handle lock sets on the cafeteria food line doors.
- 7. Repaired the lock for the gym teacher's office.
- 8. Repaired a vandalized exit sing in the sixth grade hall.
- 9. Replaced the lamp in the exterior wall pack light near the main entrance.
- 10. Replaced one light ballast and three light tubes in the girl's locker room.
- 11. Replaced the door handle for the art room.
- 12. Repaired the door handle for room C-123.
- 13. Replaced the door lock for the art room.
- 14. Replaced four defective auto flush valves.
- 15. Hung a plaque in the main hallway.
- 16. Installed new weather stripping on the front doors.
- 17. Replaced eight light tubes in the boiler room.
- 18. Replaced six light tubes in the kitchen.
- 19. Repaired the door lock for room C-116.
- 20. Repaired the door lock for room B-144.
- 21. Replaced light tubes throughout in hallways.

J. Harvey Rodgers School

- 1. Worked on overheat issues for rooms A-2 and A-10.
- 2. Replaced the valve body and actuator for the unit ventilator in room A-9.
- 3. Reset heating boiler number 2.

- 4. Replaced the ceiling tile outside of the A-wing boiler room.
- 5. Reset the freeze stat for the unit ventilator in room A-8.
- 6. Replaced the ceiling tile in the hall near B-5.
- 7. Repaired the hand rail in the B-wing staff lavatory.
- 8. Replaced broken ceiling tiles in the B-wing staff lavatory.
- 9. Replaced seven older exit signs with new LED signs.
- 10. Replaced eight ceiling tiles in the A-wing hallway.
- 11. Checked all emergency lights.
- 12. Replaced one auto flush valve in the B-wing girl's lavatory.
- 13. Repaired the lock for room A-2.
- 14. Installed a speaker in the ceiling of room A-5.
- 15. Painted ceiling tiles outside of the main office and the all purpose room.
- 16. Repaired the lock for the A-wing staff lavatory and replaced the key.

Bullock School

- 1. Completed piping repairs and replaced the wall cabinets in room A-21. Restored heat to room.
- 2. Replaced the main suction hose for the carpet machine.
- 3. Replaced the belt for the combustion air intake fan.
- 4. Tested the stand by generator and checked exit signs and emergency lights.
- 5. Replaced the faucet in room A-10.
- 6. Repaired one custodial vacuum cleaner.
- 7. Repaired the unit ventilator in room C-37.
- 8. Repaired the door handle for the door between the media center and the workroom.
- 9. Replaced the lamp in the wall pack light outside of the art room.
- 10. Replaced the lock core in one cafeteria door.
- 11. Unclogged one toilet in the third grade boy's lavatory.
- 12. Repaired the door handles for rooms A-12 and A-13.
- 13. Tightened the sink in the third grade girl's lavatory.
- 14. Cleared a clogged toilet in room D-2.
- 15. Installed a dry erase board in the technology office.
- 16. Installed two new locks on the exterior gym doors.
- 17. Tightened the electronic latch on the main entrance doors.
- 18. Replaced one light ballast and two light tubes in room C-33.

Board Office

- 1. Tested the emergency generator.
- 2. Moved technology director from the Board Office to Bullock.
- 3. Moved the HR generalist into the technology office.
- 4. Spackled holes and painted walls in the old technology office.
- 5. Assembled a new desk for the Superintendent.
- 6. Moved the Superintendent's old desk into Mrs. Sochor's office.

- 7. Moved 40 file boxes from the Board Office to the White Annex for storage.
- 8. Moved partitions around outside of the Superintendent's office.
- 9. Moved file cabinets around on the business side of the office.

Transportation Garage

No repairs to report for the month.

Brick Annex

- 1. Repaired one window shade in the STEAM room.
- 2. Repaired one exterior wall pack light.

Operations Office

- 1. Replaced the door lock on the driver's door.
- 2. Replaced four light tubes throughout.

Wood Annex

No repairs to report for the month.

The following assignments were completed by our Ground's staff:

- 1. Policed up the grounds at all facilities for trash.
- 2. Picked up and delivered inner office mail district wide every day.
- 3. Delivered custodial supplies to the schools as requested.
- 4. Handled snow and ice events with plowing and salting.
- 5. Continued prepping the baseball / softball fields for spring sports practices.