GLASSBORO PUBLIC SCHOOLS GLASSBORO, NEW JERSEY

April 18, 2018

MAINTENANCE DEPARTMENT REPORT

The following tasks were completed by our maintenance staff during the month:

Glassboro High School

- 1. Cleared a clogged sink in the kitchen.
- 2. Ran the standby generator and checked all emergency lighting.
- 3. Removed the paint sink in the auditorium and cleared a clogged drain. Replaced the sink trap as well.
- 4. Received owner training on new exhaust fans and make up air units.
- 5. Removed overhead lines from the building to the press box. Wires were abandoned telecommunications lines.
- 6. Checked the rooftop unit for room C-110.
- 7. Manually opened the heat valve for room A-137.
- 8. Replaced the outlet behind the desk in the kitchen.
- 9. Changed filters in the cafeteria air handlers and in the fan coil units.
- 10. Reset the breakers for the exterior gym lights.
- 11. Changed filters in the make-up air units.
- 12. Repaired the electric feed for the TV studio rooftop unit.
- 12. Changed filters in the air handlers for the main office, auditorium, media center and weight room.
- 13. Restored heat to room A-137.
- 14. Replaced two faucets and ran a new drain line for the ice machine in the concession stand.
- 15. Replaced one lamp in the light fixture on the corner on B-wing.
- 16. Installed a cable line for the monitor in the main entrance lobby.
- 17. Repaired the desk for the secretary in the main office.
- 18. Repaired the emergency light backstage in the auditorium.
- 19. Re-timed every classroom lock building wide.
- 20. Repaired the door closer for room A-131.
- 21. Repaired the bottom of the security officer's door.

- 22. Replaced the batteries for the flush valve in the female lavatory near room A-114.
- 23. Reinstalled the gate at the track driveway.
- 24. Relocated the fire blanket from room A-131 to room A-137.
- 25. Replaced the lamp in the little bulldog's bathroom.
- 26. Changed filters in the rooftop units for rooms A-102 and A-107.
- 27. Repaired the exit signs at the main entrance.
- 28. Repaired the center bar cleat for the girl's side gym exit doors.
- 29. Mounted new pole vault standards at the track.

Intermediate School

- 1. Checked the fan coil unit for the second floor male lavatory.
- 2. Removed circulating pump and bearing assembly for the science wing in the boiler room for repairs.
- 3. Ran the stand by generator and checked emergency lights and exit signs.
- 4. Flushed sewer vents and checked for leaks for sewer gas smell.
- 5. Replaced the light switch for room 219.
- 6. Installed an outlet for grow lights outside room 201.
- 7. Installed a new ballast and lamp in the exterior ramp light behind the building.
- 8. Repaired the door at the kitchen.
- 9. Repaired table tops in the cafeteria.
- 10. Replaced the battery in the emergency light outside of the media center.
- 11. Changed filters in the air handlers for rooms 100 and 116.
- 12. Changed filters in the hallway fan coil units.
- 13. Replaced the motor for the exhaust fan for the boy's lavatories.
- 14. Cleared a clogged toilet in the girl's locker room.
- 15. Repaired the door lock for room 206.
- 16. Flushed out sewer vents and removed leaves. Cover with screening.
- 17. Caulked around the base of toilets in the third floor boy's lavatory.
- 18. Repaired the flush valve for one toilet in the second floor boy's lavatory.

Thomas Bowe School

- 1. Checked the rooftop HVAC units every day and reset as needed.
- 2. Restored power to HVAC unit MZ-10.
- 3. Installed hasps / locks to all circuit breaker panels.
- 4. Reinstalled the burner linkage for HVAC unit MZ-2.
- 5. Tested the stand by generator and check emergency lights and exit signs.
- 6. Replaced the faucet for the kitchen steamer.
- 7. Checked the burner for HVAC unit MZ-11.
- 8. Reset the return air fan for HVAC unit MZ-11.
- 9. Repaired one custodial vacuum cleaner.
- 10. Repaired the dampers for HVAC unit MZ-10 and MZ-11.
- 11. Replaced the burner modulation motor for HVAC unit MZ-10.

- 12. Replaced one lamp in the rear exterior wall pack light near the mechanical room entrance.
- 13. Replaced the lamp in the exterior wall pack light at the main entrance.
- 14. Replaced the batteries in the flush valve for two toilets in the sixth grade boy's lavatory.
- 15. Replaced eight light tubes in the art room.
- 16. Repaired the lock for the door between the nurse and the waiting area.
- 17. Remounted the box on the power pole in rom A-104.
- 18. Replaced a vandalized toilet paper holder in the sixth grade boy's lavatory.
- 19. Repaired window screens for room B-125.
- 20. Installed locks / hasps on filing cabinets in the guidance office.

J. Harvey Rodgers School

- 1. Replaced the light ballast in the principal's office.
- 2. Replaced the light switch backstage near the steps.
- 3. Replaced the battery in the emergency light outside of the nurse's office.
- 4. Installed a new doorstop for the girl's lavatory across from room A-1.
- 5. Repaired the main entrance center bar.
- 6. Restarted all air handlers and unit ventilators for the A-wing.
- 7. Replaced the lock core for the main entrance center bar.

Bullock School

- 1. Replaced the faucet in room A-15.
- 2. Checked power for the main hall security gate. Need to replace key switch.
- 3. Replaced the lock for the art room closet.
- 4. Tested the stand by generator and checked exit signs and emergency lights.
- 5. Repaired one toilet in the girl's lavatory across from CST.
- 6. Replaced three light tubes in room D-33.
- 7. Repaired the center bar for the gym doors across from the boiler room.
- 8. Repaired the lid on one trash dumpster.
- 9. Replaced the lamp in the exterior wall pack near the kitchen.
- 10. Replaced the latches on the stage storage doors.
- 11. Cleared out the art room drain separator.
- 12. Repaired the cable gate at the D-wing playground.
- 13. Replaced the key switch for the main hall security gate.
- 14. Replaced one ceiling tile in room A-14.
- 15. Replaced four kick down door stops for the gym entrance doors.

Board Office

- 1. Tested the emergency generator.
- 2. Checked all emergency lights and exit signs.
- 3. Installed a leg and attached desk pieces for the Superintendent.
- 4. assembled a new desk chair for the Superintendent.

Transportation Garage

No repairs to report for the month.

Brick Annex

- 1. Replaced the cover on the fire alarm horn / strobe.
- 2. Replaced the unit ventilator motor in PAC 3.
- 3. Replaced filters in PAC 1, 2 and 4.
- 4. Replaced the bearings on one exhaust fan.
- 5. Cleaned leaves from gutters.
- 6. Replaced stained tiles in PAC 4.
- 7. Checked exit signs and emergency lights.

Operations Office

- 1. Replaced four light ballasts and seven light tubes.
- 2. Replaced the faucet in the female lavatory.
- 3. Replaced batteries in two exit signs.
- 4. Checked all emergency lights and exit signs.

Wood Annex

1. Began assembling additional metal shelving.

The following assignments were completed by our Ground's staff:

- 1. Policed up the grounds at all facilities for trash.
- 2. Picked up and delivered inner office mail district wide every day.
- 3. Delivered custodial supplies to the schools as requested.
- 4. Handled snow and ice events with plowing and salting.
- 5. Continued prepping the baseball / softball fields and track for spring sports practices.