

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

JUNE 2020

District Wide Projects

High School

- High School chiller repaired and up and running, cost down to \$7,700.00
- Needs new oil lines for the chiller after season is over cost around \$10,000.00
- Possible put in bond referendum for replacement 18 years old?

GIS

- TV contractor hired to hang TV's in GIS, in room 303 they drill directly into two electrical panels, which were on the other side of the wall, once directly into the buss bar. Have electrician working on cost and their company will be billed for repairs.

Bowe

- Fence for retention pond will be repaired a PO for Burger Fence, check from the trucking company SYSCO, food service, is covering entire repair bill.

Bullock

- Delivery of all LED NET ZERO bulbs and fixtures arrived today, can start working on project asap.

Rodgers

- There is an issue at Rodgers Elementary with the CO Detectors. Franklin Alarm made me aware that there were none in the main kitchen and the smaller kitchen in the APR both have gas appliances. Notified George Duthie and he confirmed they were not in the bid, so he is working on new drawings and we will need to go from there as how to proceed.

DISTRICT WIDE

- **Franklin Alarm Company has been given the ok to start monitoring and fire inspections for the district. Inspections have already started and some small issues fixed as well.**
- **New contracts for the Fire Sprinkler and Fire Extinguishers to be ok'd very soon.**
- **All work orders are being done in a timely fashion and all crews are moving along with building cleanings.**
- **All schools are looking good with the summer cleaning.**