
GLASSBORO PUBLIC SCHOOLS
DISTRICT PROJECT UPDATE
SEPTEMBER 2020

District Wide Projects

High School

- Preseason boiler preventative maintenance, Benchmark boiler tubes cleaned for more efficiency
- Hallway Bulletin Boards being replaced, found possible Transite Asbestos Boards, EDI will look at them and test them and the glue.

GIS

- Brick Annex family of squirrels caught and removed by staff.
- White annex building behind GIS is continuing to fall into disrepair more and more. Raccoons have gotten back in and roof is leaking, whole by chimney, and drop ceiling has fallen in. Need to find a place to store the documents and think about demolition of this structure.

Bowe

Bullock

- Final reports for two small issues with mold completed and sent to Superintendent and Business Administrator as well as the Principal.
- Starting phase of LED lightning is in the process of being installed in throughout the building.

Rodgers

Beach Admin.

- Issue with fire and burglar alarm, bad POTS line. Issue fixed with Franklin Alarm we are now using cellular system for the two systems.

DISTRICT WIDE

- Back ordered supplies still coming in and we should be fine for the Hybrid start up in November. Will continue to make sure we are well stocked.
- All district floors, walls, and entrances continued to be marked with social distancing guidelines, tape, arrows, signs and more.
- All work orders are being done in a timely fashion and all crews are continuing with building cleaning and disinfecting.
- Elections to be held at Bullock and the High SCHOOL ON November the 3rd. We will do a heavy cleaning in those areas the next day.
- rSchooltoday Facilities Scheduling and Maintenance Work Orders program. These two programs would help the district with rental and buildings usage and would help myself with electronic workorders and better reporting for the Superintendent and the Board as well as the State of NJ.
- Custodial Staff in the district is working on small projects to keep everyone busy, painting is one of the biggest things being done.