

---

---

GLASSBORO PUBLIC SCHOOLS  
DISTRICT PROJECT UPDATE  
JUNE 2021

---

---

## District Wide Projects

### High School

- High School Press Box repairs just about complete, cost about \$700.00, doing finishing touches. The only thing left is to try to finish and repair the outside siding.
- Graduation went off with no issues, believe everyone was happy with the way things looked.
- Donated benches for the tennis courts have arrived, will work with the township on how we can install without ruining the new courts.
- Gross Construction has repaired most of the cracks one more needs to be done which was missed.
- Trying to get some help with creating the Culinary Arts room in the high school and how to move forward.

### GIS

- Intermediate chiller having issues with power and the contactors to start the unit. They are “chattering” which is usually a sign of low power coming into the unit causing the contactors not to grab but go in and out causing the “chatter” and frying the contact points. Unit is now working trying to find out if AC Electric is causing the issue from Brown Outs or Power saving issues.

### Bowe

### Bullock

- NetZero LED lighting continues to be installed in the building. We are down to the last few items which includes the parking lot lights.

### Rodgers

- .

## **Beach Admin.**

### **DISTRICT WIDE**

- rSchooltoday electronic work orders up and running, since we started 269 work orders have been generated and approximately 30 still outstanding. Over the summer I will start to create PM and HAVC maintenance work orders. Also give more accurate locations for the items that need to be fixed so maintenance can go directly to the problem and not ask where.
- Wayman Fire Protection is taking over for fire and burglar alarms and testing. Just received the info they needed from Franklin Alarm.