
GLASSBORO PUBLIC SCHOOLS
DISTRICT PROJECT UPDATE
AUGUST 2021

District Wide Projects

High School

- High School boy's locker room bathroom needs major repair more work than our staff can handle, price received, and PO issued
- High School Press Box is complete and looks great.
- We lost the freezer at the high school at some point in one of the storms, insurance paid the claim for food loss, manpower and maintenance repairs.

GIS

- Environmental testing was completed and waiting on final report

Bowe

- Hot water heater repaired new parts installed.

Bullock

- Both Hot Water heaters are leaking and failed our insurance inspections, getting quotes to replace with newer and more efficient equipment.

Rodgers

Beach Admin.

- A/C was down needed new belt in air handler and unit needed to be reset.

DISTRICT WIDE

- rSchooltoday electronic work orders, 377 work orders have been generated and approximately 49 still outstanding, most outstanding are from school being back in session and things needing put together and smaller repairs, work orders coming in daily.

- Wayman Fire Protection has taken over for the fire and burglar monitoring and testing.
- All district fire extinguishers have been inspected and any repairs done, including the ones on the buses.
- All district fire alarms have been inspected as well as all district sprinkler systems.
- All school now have Medify HEPA units in their cafeterias and special areas with children having a tough time keeping masks on.