

GLASSBORO PUBLIC SCHOOLS

DISTRICT PROJECT UPDATE

October 2022

District Wide Projects

High School

- All home economics equipment has been delivered and installed. Suppression Hood to be tested 11/9 and inspected 11/10
- Library construction started.
- Roof leaks, PO created to fix the one leak in the hallway.
- New Cafeteria tables and booths delivered and set up

Bowe

- FIRE ALARM ISSUES PANEL NOT WORKING IN DISABLED MODE. Fire alarm was temporarily repaired, 106 troubles down to 6 or so, there is a wire that has been cut or the wire nicked and not powering the others. Wayman wants to wait for construction to be done to find issue, we are up, and work and alarm will go off and alert dispatch.
- A few small roof leaks, one in the construction area.
- Two rooftops at Bowe under the emergency purchase, we have been notified they are delayed do not have a date s of yet for delivery.
- New cafeteria tables delivered and set up.

Bullock

- Pricing on new through the wall units for room C15 to replace two old units. NorthEast Mechanical awarded quote, unfortunately the units are 16-18 weeks out as of now.
- Gym curtain installed; PO created for power to curtain.
- We have at least two units the drain pans are leaking. They must be completely torn apart to repair/replace the pans. D-7 and A-20
- Reported smell of mold in A-8 by district employee during back-to-school night. Tests were run by EDI and found there was no mold issue in the room. The smell was from Fig tree and other debris in garden area.
- Leak in the Art room, we believe due to gutter overflowing in the corner.
- New cafeteria tables delivered and set up.

Rodgers

- Roof leak in the copy room of the main office, PO issued for the repair of this leak.
- Coil leak in room A-1 working on quote for replacement. PO issued for this repair to NorthEast Mechanical.
- New cafeteria tables delivered and set up.

BEACH

- Some roof leaks due to all the rain, BA'S office right hand corner. Waiting for roofer to come out and inspect as well as other smaller leaks in district.

OPS/TRANSPORTATION

- **New door for bus drivers to be installed on the 18th with FOB access, more secure for OPS**

DISTRICT WIDE

- rSchooltoday electronic work orders, 1263 work orders have been generated and approximately 45 still outstanding, most outstanding are from school heating issues and things needing put together and smaller repairs, work orders coming in daily.
- 12 containers now in district for storage of items removed from GIS and other buildings.
- Summer help has been amazing hope to repeat this next year.
- Working on Bond Referendum, principals wish list, last \$10 million bond referendum we were working on give ideas of priority of work.