

## GLASSBORO PUBLIC SCHOOLS

### DISTRICT PROJECT UPDATE

November 2022

#### District Wide Projects

##### High School

- All home economics equipment has been delivered and installed, system up and running and being used by the teacher and students
- Library construction started.
- Roof leak, repaired.

##### Bowe

- FIRE ALARM Now working 100%
- A few small roof leaks, one in the construction area.
- Two rooftops at Bowe under the emergency purchase, we have been notified they are delayed do not have a date s of yet for delivery.
- Floor tiles laid, cabinetry delivered and installed along with counter tops.
- Locker room floor poured.

##### Bullock

- Pricing new through the wall units for room C15 to replace two old units. NorthEast Mechanical awarded quote, unfortunately the units are 16-18 weeks out as of now.
- Gym curtain installed; PO created for power to curtain.
- We have at least two units the drain pans are leaking. They must be completely torn apart to repair/replace the pans. D-7 and A-20. PO will be issued using Federal money.
- Leak in the Art room, we believe due to gutter overflowing in the corner.
- Price on replacing Nurse's office old and noisy air handler with Federal money

##### Rodgers

- Roof leak in the copy room of the main office, Repaired
- Coil leak in room A-1 working on quote for replacement. PO issued for this repair to NorthEast Mechanical.

- RTU air make up units now both are up and running.

## **BEACH**

- Some roof leaks due to all the rain, BA'S office right hand corner. Waiting for roofer to come out and inspect as well as other smaller leaks in district.
- Price on fixing HVAC in building, return air is pulling from above ceiling no returns coming into working space, causing issues with all cold or all hot air being pulled back to the system. New returns into working space and fixing some supply ducts as well.

## **OPS/TRANSPORTATION**

- **New door for bus drivers to be installed on the 18<sup>th</sup> with FOB access, more secure for OPS. Done!**

## **DISTRICT WIDE**

- rSchooltoday electronic work orders, 1322 work orders have been generated and approximately 48 still outstanding, most outstanding are from school heating issues and things needing put together and smaller repairs, work orders coming in daily.
- 12 containers now in district for storage of items removed from GIS and other buildings.
- Working on Bond Referendum, principals wish list, last \$10 million bond referendum we were working on give ideas of priority of work.
- Working shorthanded, district wide and commend those who have stepped up to make sure we keep moving by helping wherever needed
- Losing my Grounds foreman Frank Gullo at the end of December, this is a huge loss to the district and athletic program.